



VERIFICATION OF COMPLIANCE

This Verification of Compliance is hereby issued to the below named company and for below described product, based on

**Technical Standard : EMC DIRECTIVE 2014/30/EU
(EN 61000-6-4 / EN 61000-6-2)**

General Information

Applicant : NOVAKON
Address of Applicant : Bldg.G, 4F, No.3-1, Yuan Qu Street Nankang,
Taipei 11503, Taiwan (R.O.C)

Product Description

Product Name : Human Machine Interface
Brand Name : **NOVAKON**
Model Number : P04-N; P04x-N; P04; P04x

Measurement Standard

EN 61000-6-4: 2007 + A1: 2011
EN 61000-3-2: 2014
EN 61000-3-3: 2013
EN 61000-6-2: 2005 / AC: 2005
(IEC 61000-4-2: 2008; IEC 61000-4-3: 2006 + A1: 2007 + A2: 2010; IEC 61000-4-4: 2012;
IEC 61000-4-5: 2014; IEC 61000-4-6: 2013; IEC 61000-4-8: 2009; IEC 61000-4-11: 2004)

Measurement Facilities

Company Name : **Compliance Certification Services Inc.**
Test Laboratory : Xindian Lab.
Address of Test Lab. : No.163-1, Jhongsheng Rd., Xindian Dist., New Taipei City, 23151 Taiwan.

This device has been tested and found to be in compliance with the measurement procedures specified in the Standards & Specifications listed above and as indicated in the measurement report with the number: T171211D03-E

The test results shown in this report are applicable only to the investigated sample identified in this report.

Sam Hu / Assistant Manager
Date: December 13, 2017