

User Information

Correct Use

The ESM-BA7.. is a universal emergency stop safety switching device with seven safe relay outputs that can quickly and safely stop the moving parts of a machine or system in case of danger.

Applications for the ESM-BA7.. include single or dual-channel emergency stop circuits and guard monitoring on machines and systems. This safety relay can be delivered with fixed screw terminals or plug-in terminals.



Features

- 7 safe, redundant relay outputs
- 4 auxiliary relay outputs; 2 auxiliary transistor outputs
- Connection of:
 - Emergency stop buttons
 - Safety switches
 - Non-contact safety switches
 - OSSD-Outputs
- Single or dual-channel operation possible
- Feedback loop for monitoring downstream contactors or expansion modules
- Cyclical monitoring of the output contacts
- Indication of the switching state via LED
- 2 start behavior possible:
 - Monitored manual start
 - Automatic start
- Up to PL e, SILCL 3, category 4
- STOP-category: 0

Function

The emergency stop safety switching device ESM-BA7.. is designed for safe isolation of safety circuits according to EN 60204-1 and can be used up to safety category 4, PL e according to EN ISO 13849-1.

The internal logical system closes the safety contacts when the start button is pressed.

If the safety switch is opened, the positively driven safety contacts are opened and safely switch the machine off. It is ensured that a single fault does not lead to a loss of the safety function and that every fault is detected by cyclical self-monitoring no later than when the system is switched off and switched on again.

The operating status of the device is indicate by the auxiliary transistor outputs O1 and O2

O1: Ready. PWR is connected.

O2: Both relay channel K1, K2 are switched on.




Fig. 1 Block diagramm ESM-BA7..

Installation

As per EN 60204-1, the device is intended for installation in control cabinets with a minimum degree of protection of IP54. It is mounted on a 35-mm DIN rail according to DIN EN 60715 TH35.




Fig. 2 Installation / removal


Safety Precautions



- Installation and commissioning of the device must be performed **only by authorized personnel**.
- Observe the country-specific regulations when installing the device.
- The electrical connection of the device is only allowed to be made with the device isolated.
- The wiring of the device must comply with the instructions in this user information, otherwise there is a risk that the safety function will be lost.
- It is not allowed to open the device, tamper with the device or bypass the safety devices.
- All relevant safety regulations and standards are to be observed.
- The overall concept of the control system in which the device is incorporated must be validated by the user.
- Failure to observe the safety regulations can result in death, serious injury and serious damage.
- Note down the version of the product (see label "Vx.x.x") and check it prior to every commissioning of a new device. If the version has changed, the overall concept of the control system in which the device is incorporated must be validated again by the user.

Electrical Connection

- A safety transformer according to IEC 61558-2-6 or a power supply unit with electrical isolation from the mains must be connected.
- External fusing of the safety contacts (6A slow-blow or 8A quick-action or 10 A gG) must be provided.
- A maximum length of the control lines of 1000 meters with a line cross section of 0.75 mm² must not be exceeded.
- The line cross section must not exceed 2.5 mm².
- If the device does not function after commissioning, it must be returned to the manufacturer unopened. Opening the device will void the warranty.



- A1: Power Supply
- A2: Power Supply
- S11: DC 24V control voltage
- S10: Control line
- S12: Control line
- S13: Control line
- S14: Control line
- S21: Start, Control line
- O1, O2: Aux transistor outputs
- 0V: Reference common O1, O2
- 81-82: Auxiliary Contact
- 91-92: Auxiliary Contact
- 101-102: Auxiliary Contact
- 101-112: Auxiliary Contact
- 13-14 to 73-74: Safety Out1-7

Fig. 3 Connections

User Information

Applications

Depending on the application or the result of the risk assessment according to EN ISO 13849-1, the device must be wired as shown in Fig. 1 to Fig. 11.

Emergency Stop Circuit




Fig. 1:
Two-channel emergency stop circuit with short circuit and earth fault monitoring.
(category 4, up to PL e)




Fig. 2:
Two-channel emergency stop circuit with earth fault monitoring.
(category 3, up to PL d)




Fig. 3:
Single-channel emergency stop circuit with earth fault monitoring.
(category 1, up to PL c)




Fig. 4:
Two-channel sliding guard monitoring with short circuit and earth fault monitoring.
(category 4, up to PL e)




Fig. 5:
Two-channel emergency stop with prp-outputs/OSSD-outputs with short circuit monitoring.
(category 4, up to PL e)

Warning only for 24V-version:

In order to activate earth fault monitoring, the PE must be connected only to the power supply unit in accordance with EN60204-1.

Starting Behavior




Fig. 6:
Monitored manual start.
It is monitored that the start button was opened before the emergency stop button closes. (Prerequisite: operating voltage must not be interrupted.)




Fig. 7:
Automatic start.
Max. permitted delay during closing of the safety switches on S12 and S13:
S12 before S13: 300 ms
S13 before S12: any

Warning:
Safety contacts switch immediately when the power supply is connected.

Feedback Loop




Fig. 8:
Feedback loop for monitored manual start:
The feedback loop monitors contactors or the expansion modules.




Fig. 9:
Feedback loop for automatic start:
The feedback loop monitors contactors or the expansion modules.

Power supply and Safety contacts




Fig. 10:
Power supply A1 and A2.
(Power supply according to techn. data)




Fig. 11:
Connecting load to safety contacts.
(Figure shows example. Voltage „+V“ according to techn. data)

Commissioning Procedure

Note: The items listed under "Electrical connection" must be observed during commissioning.

1. Wiring emergency stop circuit:

Wire the emergency stop circuit according to the required Performance Level determined (see Fig. 1 to Fig. 5).

2. Wiring start circuit:

Wire the start circuit according to Fig. 6 or Fig. 7 to set the starting behavior.

Warning:

If "Automatic start" is set, bear in mind that the safety contacts will switch immediately after the power supply is connected. If "monitored manual start" is set, the start button must be opened after wiring.

3. Wiring feedback loop:

If your application provides for external contactors or expansion modules, connect them to the device according to Fig. 8 or Fig. 9.

4. Wiring power supply:

Connect the power supply to terminals A1 and A2 (Fig. 10).

Warning: Wiring only in de-energized state.

5. Starting the device:

Switch on the operating voltage.

Warning:

If the "automatic start" starting behavior is set, the safety contacts will close immediately.

If the "monitored manual start" starting behavior is set, close the start button to close the safety contacts.

LEDs **K1** and **K2** are lit.

6. Triggering safety function:

Open the emergency stop circuit by actuating the connected safety switch. The safety contacts open immediately.

7. Reactivation:

Close the emergency stop circuit. If "automatic start" is selected, the safety contacts will close immediately.

If the "monitored manual start" starting behavior is set, close the start button to close the safety contacts.



User Information

Maintenance

The device must be checked once per month for proper function and for signs of tampering and bypassing of the safety function.

The device is otherwise maintenance free, provided that it was installed properly.

What to Do in Case of a Fault?

Device does not switch on:

- Check the wiring by comparing it to the wiring diagrams.
- Check the safety switch used for correct function and adjustment.
- Check whether the emergency stop circuit is closed.
- Check whether the start button (with manual start) is closed.
- Check the operating voltage at A1 and A2.
- Is the feedback loop closed?

Device cannot be switched on again after an emergency stop:

- Check whether the emergency stop circuit was closed again.
- Was the start button opened before closing of the emergency stop circuit (with manual start)?
- Is the feedback loop closed?

If the fault still exists, perform the steps listed under "Commissioning Procedure".

If these steps do not remedy the fault either, return the device to the manufacturer for examination.

Opening the device is impermissible and will void the warranty.

Safety Characteristics According to EN ISO 13849-1

The device is certified according to EN ISO 13849-1 up to a Performance Level of PL e.

Note:

Additional data can be requested from the manufacturer for applications that deviate from these conditions.

Safety characteristics according to EN ISO 13849-1 for all variants of ESM-BA7			
Load (DC-13; 24V)	<= 0.1 A	<= 1 A	<= 2 A
T10d [years]	20	20	20
Category:	4	4	4
PL	e	e	e
PFHd [1/h]	2.47E-08	2.47E-08	2.47E-08
nop [cycle / year]	<= 500.000	<= 350.000	<= 100.000

Techn. Data


Operating voltage	AC/DC 24 V
Rated supply Voltage	50-60 Hz
Permissible deviation	+ / - 10 %
Power consumption	DC 24 V AC 24 V approx. 4.5 W approx. 8.5 VA
Control voltage at S11	DC 24 V
Control current S11..S14	approx. 250 mA
Safety contacts	7 NO contacts
Auxiliary contacts	4 NC contacts
Auxiliary transistor outputs (O1, O2)	DC 24 V / 30 mA, over current protected
Max. switching voltage	AC 250 V
Safety contact breaking capacity (13-14, 23-24, 33-34,43-44, 53-54, 63-64, 73-74)	AC: 250 V, 2000 VA, 8 A for ohmic load 250 V, 3 A for AC-15 DC: 50 V, 8 A for ohmic load 24 V, 3 A for DC-13 Max. total current through all 7 contacts up to Ta=40 °C: 35 A 10 mm spacing between the devices 20 A no spacing between the devices
Auxiliary contacts braking capacity (81-82, 91-92, 101-102,101-112)	AC: 250 V, 2000 VA, 8 A for ohmic load
Minimum contact load	24 V, 5 mA
Contact fuses	6 A slow blow or 8 A quick-action or 10 A gG
Line cross section	0.14 -2.5 mm ²
Max. length of control line	1000 m at 0.75 mm ²
Contact material	AgSnO ₂
Contact service life	mech. approx. 1 x 10 ⁷
Test voltage	2.5 kV (control voltage / contacts)
Rated impulse withstand voltage, leakage path/air gap	4 kV (DIN VDE 0110-1)
Rated insulation voltage	250 V
Degree of protection	IP20
Temperature range	-15 °C bis +40 °C
Degree of contamination	2 (DIN VDE 0110-1)
Overvoltage category	3 (DIN VDE 0110-1)
Weight	approx. 350 g
Mounting	DIN rail according to EN 60715TH35

V1.1.0


User Information

Dimension
Drawing

Fixed
Terminals



Plug-In
Terminals



Subject to technical modifications, no responsibility is accepted for the accuracy of this information. © EUCHNER GmbH + Co. KG 090093-04-04/15 (Translation of the Original Operating Instructions)